

KAWASAKI STEEL TECHNICAL REPORT

No.25 (September 1991)

*Special Issue on 'H-Shapes with
Fixed Outer Dimension' and 'Steel Pipe'*

Transient Flow Analysis for the Management of Water Pipeline Network System

Takeshi Koike, Toshio Imai, Tadashi Teramoto, Minoru Suzuki, Shota Miyake

Synopsis :

A computer program is described for the transient flow analysis of water pipeline networks. This program was developed by Kawasaki Steel to simulate transient phenomena in a complete water pipeline, including valves, pumps, reservoirs and leakage points. In order to check the accuracy of this program, a field test was run on an existing water transmission pipeline in Ishikawa prefecture. The numerical analysis show good agreement between experimental data and simulated results within a maximum error of 3.7% in pressure. This program can play an important role in managing a large-scale water pipeline network when used as part of the lifeline information management system (LIMAS), which was developed by computer mapping techniques. This flow analysis program extends the applicability of LIMAS to many fields of waterworks such as future water supply planning, short-term flow prediction in daily operation, and leakage flow control.

(c)JFE Steel Corporation, 2003

The body can be viewed from the next page.

Transient Flow Analysis for the Management of Water Pipeline Network Systems*



Synopsis:

A computer program is described for the transient flow analysis of water pipeline networks. This program was developed by Kawasaki Steel to simulate transient flow in

2.1 Formula for Steady Flow

θ : Angle of pipe inclination

g : Acceleration due to gravity

Consider a steady state flow in a single pipe with a node at each end. The water head (H) and flow rate (Q)

Here, a in Eq. (8) is the velocity of the pressure wave given by Eq. (9) in which elastic deformation of the

specifications of the valve and data on the valve

wide variety of characteristic data on the pipeline

open ratio.

(4) Leak point makes it possible to simulate leakage by defining the diameter of the leakage hole or detection

can be easily handled by the RDB incorporated in the mapping system.

(7) Once the RDB has been constructed, the facility can

the leak flow rate

be managed for its daily maintenance operations.





Table 1 Pipeline specifications

No.	Link ID	Dia. (mm)	Length (m)
1	L-01	1 800	1 142
2	L-02	300	217
3	L-03	1 800	829
4	L-04	1 350	274
5	L-05	1 350	274
6	L-06	1 800	264
7	L-07	1 350	286
8	L-08	1 350	286



15 000



synchronized demand flow changes ($t = 100$ s), and these waves spread to the other points after some delay. The characteristics of these pressure waves are similar

reservoirs shown in Fig. 8 on the other hand, the pres- cm² it must be noted that these phenomena should be

sure amplitude was slower to decrease, taking more than 400 seconds until the flow conditions returned to their steady state. Since the maximum amplitude of

avoided in order to protect the pipeline system from structural damage.